




Punjab Fire Services
(Dera Bassi)



FIRE SAFETY CERTIFICATE
ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No 1501-100632-Fire/76438

NOC Type: Renew

Dated **01-Oct-2024**

Certified that the A C Global School at Hulka Road Village Banur Distt SAS Nagar comprised of 0 basements and 2 (Upper floor) owned/occupied by Saurabh Agnihotri have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **01-Oct-2024** in the presence of **Mr Rajan Popli** (Name of the owner or his representative) and that the building / premises is fit for occupancy group B subdivision B-1 (As per NBC) for period of one year from issue date. Subject to the following conditions.

Issued on **01-Oct-2024** at **Dera Bassi**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **A C Global School** ਜੋ ਕਿ **Hulka Road Village Banur Distt SAS Nagar** ਸਮੇਤ 0 ਬੇਸਮੈਂਟ ਅਤੇ 2 (ਉੱਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **Saurabh Agnihotri** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਊ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **01-Oct-2024** ਮੌਜੂਦਗੀ ਵਿੱਚ **Mr Rajan Popli** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group B subdivision B-1 (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ ਇੱਕ ਸਾਲ ਤੱਕ ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **01-Oct-2024** ਕਿੱਥੇ **Dera Bassi**.

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ/ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.

ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂੰ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।

4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.

ਫਾਇਰ ਬ੍ਰਿਗੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.

ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

* Above Details cannot be used as ownership proof.

Director
A.C. Global School
Banur

President
C. Educational & Welfare Soc.

Principal
A.C. Global School
Banur



ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitally created certificate, no signature are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਾਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

Inspection Report by Fire Officer

PROFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE & SAFETY MEASURES (high rise/ multistory buildings, hospitals, nursing-homes, corporate offices, factories and hazardous storages)		Date of Inspection
Sr. No.	Detail of Building /Premises	Detail of Building /Premises /Fire safety measures
1	Name of the Building/ Premises (Location-Address)	A C Global School Hulka Road Banur Teh Dera Bassi Distt S A S Nagar
2	Name & address of the owner with contact no. (s)	Mr. Saurabh Agnihotri
3	Name & address of occupier (s) with contact no. (s)	As Above
4	Total area of the Premises	4705 Sq Mtrs
5	Total covered area	3605 Mtrs
6	Height of the building from ground level	7 Mtrs
7	Number of basements & its Area	No Basement
8	Number of sanctioned floors	Ground + One Storey
9	Number of actual floors	As Above
10	Parking area	Open Parking
11	Details of surrounding Properties a) front side b) Right side c) Left side d) Back side	Road Other Property Other Property Other Property
12	Number of main gates with size	2 No
13	Number of fire extinguisher installed in the building on each floor with capacity, type with ISI marking number and date of manufacturing	Co ₂ Type Each Floors = 1 No ABC Type Each Floors = 2 Nos Bucket Stand = 02 Nos
14	Detail of Hose reel on each floor indicating size and length of rubber pipe	Each Floor 1 Nos With 30 Mtr length
15	Details of wet riser. No. of landing valve, delivery hose, branch pipe and hose cabinet in each floor	N/R
16	No. of yard hydrant with details	N/R
17	Whether basement is being used for parking, storage or office. Has the basement sprinkler system? Give all details	No Basement
18	No. of manual fire alarms installed in the building	N/R
19	Details of automatic fire detection system. P.A. system provided in the building	N/R

Sprihatie
Director
A.C. Global School
Banur

Shishma Agnihotri
President
A.C. Educational & Welfare Society
Larakpur

Princip
A.C. Global School
Banur